

c 30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No F6/DFS/MS/SZ/2024/School/1097

Dated: 06/11/2024

FIRE SAFETY CERTIFICATE

Certified that the building Gyan Sagar public school Located at Raj Nagar - II, Palam colony, New Delhi - 110077, comprised of Ground + 3 Upper floors was issued FSC vide Letter No. F6/DFS/MS/SZ/2021/762 dated 21/09/2021. The premises was re inspected by the officers concerned of this department on 25/10/2024 in the presence of Sh. S B Yadav (Employee) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi circular No: 262 - 362 dated 17/01/2005 and that the premises is fit for occupancy class B "Educational building" with effect from 06/11/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on ... 06/11/2024 at New Delhi by.

mk yadav
Principal
Gyan Sagar Public School
(S. Sec. Recognised)
D-Block, Raj Nagar-II, (Extn.)
Palam Colony, New Delhi-110077.
Copy to:

[Signature]
(Atul Garg)
Director
Delhi Fire Service.
[Signature]

- 1 The Principal, Gyan Sagar public school Raj Nagar - II, Palam colony, New Delhi - 110077
- 2 The Directorate of Education Old Secretariat Delhi - 110054

Condition for the validity of fire safety certificate:-

- 1 The staircase at terrace level shall be kept open & free from lock and key & all the exit shall be clear from any obstruction otherwise the FSC shall be null & void.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4 The trained staff should be available round the clock.
- 5 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in
- 8 Basement if any shall be used strictly as per building bye laws.
- 9 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.